



令和4年1月 騒音・振動測定値報告



工場内配置図



測定項目	規制基準値	1/5(水)		1/12(水)		1/19(水)		1/26(水)	
		10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10
騒音L05 dB	85.0	62.8	62.7	63.0	62.5	61.4	62.2	61.6	60.8
振動L10 dB	75.0	38.8	38.1	39.9	41.5	43.7	38.3	38.8	40.4