




令和3年2月 騒音・振動測定値報告



工場内配置図



測定項目	規制基準値	2/3(水)		2/10(水)		2/17(水)		2/24(水)	
		10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10
騒音L05 dB	85.0	64.7	63.0	62.3	64.4	66.1	68.1	68.0	62.3
振動L10 dB	75.0	42.8	41.6	42.2	45.1	42.3	44.6	43.4	42.2