




令和元年10月 騒音・振動測定値報告



工場内配置図



測定項目	規制基準値	10/2(水)		10/9(水)		10/16(水)		10/23(水)		10/30(水)	
		10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10
騒音L05 dB	85.0	70.4	68.9	70.3	69.4	60.4	61.4	61.9	62.6	61.1	59.6
振動L10 dB	75.0	39.4	39.8	39.6	39.3	39.0	41.8	39.2	40.4	40.7	40.9