



# 令和3年6月 騒音・振動測定値報告



工場内配置図



測定項目	規制基準値	6/2(水)		6/9(水)		6/16(水)		6/23(水)		6/30(水)	
		10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10
騒音L05 dB	85.0	62.2	63.7	63.3	61.2	65.9	64.9	61.6	63.6	67.7	60.3
振動L10 dB	75.0	40.9	39.2	39.2	39.0	39.6	39.1	41.8	40.7	39.3	38.6