




令和元年11月 騒音・振動測定値報告



工場内配置図



測定項目	規制基準値	11/6(水)		11/13(水)		11/20(水)		11/27(水)	
		10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10
騒音L05 dB	85.0	60.4	60.9	62.4	61.6	61.4	61.6	65.6	61.6
振動L10 dB	75.0	42.6	39.9	39.5	39.3	40.0	39.3	44.5	41.4