




# 令和4年11月 騒音・振動測定値報告



工場内配置図



測定項目	規制基準値	11/2(水)		11/9(水)		11/16(水)		11/23(水)		11/30(水)	
		10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10
騒音L05 dB	85.0	68.2	67.2	62.9	67.2	66.6	62.2	65.5	65.7	74.4	63.9
振動L10 dB	75.0	45.6	50.9	46.4	50.6	47.7	45.2	45.1	46.0	45.3	44.6