



令和4年9月 騒音・振動測定値報告



工場内配置図



測定項目	規制基準値	9/7(水)		9/14(水)		9/21(水)		9/28(水)	
		10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10
騒音L05 dB	85.0	61.3	64.0	62.7	72.6	63.3	62.6	63.5	62.9
振動L10 dB	75.0	41.6	41.7	43.1	42.6	41.1	40.3	44.1	41.0